



## **PROCEDURE FOR INSTALLATION OF GENERATOR SET** **ROOF TOP OF COMMERCIAL BUILDINGS**

1. The Owner / Tenant shall obtain permission from DHA for installation of generator set on the rooftop of the Commercial Buildings in DHA area.
2. Application alongwith NOC from the Owner/ Tenant shall be submitted in the office of Secretary Technical & Chief Engineering / Additional Director (Planning & Coordination) alongwith Stability Certificate from a qualified structural engineer and affidavit that Owner / Tenant will compensate damage to the person / property of other if caused due to improper erection of the generator and that the Owner / Tenant shall remove the generator without any claim / charges as and when ordered by the Authority.
3. Generator set 25 KVA – 100 KVA for 4 – 8 Marla and for 16 Marla and above more than 100 KVA but maximum 400 KVA will be allowed on the roof top of Commercial Building subject to the fulfillment of all the formalities.
4. Properly constructed sound proof canopy will be provided with generator set to avoid noise pollution.
5. Generator set will be used as standby source only.
6. Generator set will be of diesel generators only.